

SUMMER 2019 - RESULTS FOR TESTING OF LEAD IN WATER LEVELS AT ELEVEN APS SI  
(THIRD BATCH IN THREE YEAR CYCLE SHOWN IN THIS 'MAINTENANCE' WEB SECTION)

Collect Date	Site/Location	Param	In Parts/Billion- PPB	
			Method	Result
5/24/2019	Wakefield - 3 Compartment Kitchen Sink	Lead	EPA 200.8	ND
5/24/2019	Wakefield - Cafeteria Bottle Filler	Lead	EPA 200.8	ND
5/24/2019	Wakefield - Clinic Sink	Lead	EPA 200.8	1.7
5/24/2019	Kenmore - 3 Compartment Kitchen Sink	Lead	EPA 200.8	0.4
5/24/2019	Kenmore - Cafeteria Fountain	Lead	EPA 200.8	ND
5/24/2019	Kenmore - Clinic Sink	Lead	EPA 200.8	0.4
5/24/2019	Career Center - Cullinary Sink	Lead	EPA 200.8	1.1
5/24/2019	Career Center - Fountain By Clinic	Lead	EPA 200.8	ND
5/24/2019	Career Center - Clinic Sink	Lead	EPA 200.8	1.2
5/29/2019	Langston - 3 Compartment Kitchen Sink	Lead	EPA 200.8	0.6
5/29/2019	Langston - Fountain By 115	Lead	EPA 200.8	ND
5/29/2019	Langston - Fountain By 315	Lead	EPA 200.8	ND
5/29/2019	Yorktown - Bottle Filler By Main office	Lead	EPA 200.8	ND
5/29/2019	Yorktown - Clinic Bubbler	Lead	EPA 200.8	ND
5/29/2019	Yorktown - 3 Compartment Kitchen Sink	Lead	EPA 200.8	3.5
5/29/2019	Discovery - Clinic Sink	Lead	EPA 200.8	ND
5/29/2019	Discovery - Cafeteria Bottle Filler	Lead	EPA 200.8	ND
5/29/2019	Discovery - 3 Compartment Kitchen Sink	Lead	EPA 200.8	ND
5/30/2019	Reed - 3 Compartment Kitchen Sink	Lead	EPA 200.8	0.7
5/30/2019	Reed - Clinic Sink	Lead	EPA 200.8	0.2
5/30/2019	Reed - Fountain By 1115	Lead	EPA 200.8	ND
5/30/2019	Wash-Liberty - 3 Compartment Kitch. Sink	Lead	EPA 200.8	0.3
5/30/2019	Wash-Liberty - Bottle Filler By 1600	Lead	EPA 200.8	ND
5/30/2019	Wash-Liberty - Bottle Filler By 1008	Lead	EPA 200.8	ND